# OMRON

# Switch Mode Power Supply S8VK-G (15/30/60/120/240/480-W Models)

## Reliable and Easy Operation-Worldwide Power Supply Resistant in tough environments Easy and fast installation The most compact class on the market

- Universal input for worldwide applications: 100 to 240 VAC (85 to 264 VAC)
- DC input can be available: 90 to 350 VDC
- Possible for 2-phase input usage.
- Wide operation temperature range: –40 to 70 °C
- Power Boost function at 120%
- Safety standards: UL508/62368-1, CSA C22.2 No. 107.1/62368-1 EN50178, EN62368-1. Lloyd's standards, EN60204-1 PELV Safety of Power Transformers: EN61558-2-16
- 15-W,30-W, and 60-W models conform to UL Class 2 output Standards
- EMS: EN 61204-3 EMI: EN 61204-3 Class B
- Five years Warranty







▲ Refer to Safety Precautions for All Power Supplies and Safety Precautions on page 17.



## **Model Number Structure**

## Model Number Legend

Note: Not all combinations are possible. Refer to List of Models in Ordering Information, below.



1. Input voltage type

G: Single phase

2. Power Ratings 015: 15 W 030: 30 W 060: 60 W 120: 120 W 240: 240 W 480: 480 W

3. Output voltage (VDC) 05: 5 V 12: 12 V 24: 24 V 48: 48 V 4. Option

None: Standard model 400: Coationg

## **Ordering Information**

Note: For details on normal stock models, contact your nearest OMRON representative.

Power ratings	Input voltage	Output Voltage (VDC)	Output current	Boost Current	Model number
		5 V	3 A	3.6 A	S8VK-G01505
15 W		12 V	1.2 A	1.44 A	S8VK-G01512
		24 V	0.65 A	0.78 A	S8VK-G01524
	_	5 V	5 A	6 A	S8VK-G03005
30 W		12 V	2.5 A	3 A	S8VK-G03012
	Single phase 100 to 240 VAC	24 V	1.3 A	1.56 A	S8VK-G03024
20.14/		12 V	4.5 A	5.4 A	S8VK-G06012
60 W	90 to 350 VDC	24 V	2.5 A	3 A	S8VK-G06024
120 W		24 V	5 A	6 A	S8VK-G12024
240.144		24 V	10 A	12 A	S8VK-G24024
240 W		48 V	5 A	6 A	S8VK-G24048
100.11/		24 V	20 A	24 A	S8VK-G48024
480 W		48 V	10 A	12 A	S8VK-G48048

## **Specifications**

## **Ratings, Characteristics, and Functions**

		Power rating		15 W			30 W		
Item		Output voltage (VDC)	5 V	12 V	24 V	5 V	12 V	24 V	
Efficiency		230 VAC input *6	77% typ.	77% typ.	80% typ.	79% typ.	82% typ.	86% typ.	
<b>*</b>	Voltage range *1	•	Single-phase, 85 t		350 VDC *10				
	Frequency *1		50/60 Hz (47 to 450 Hz)						
		115 VAC input *6	0.32 A typ.	0.3 A typ.	0.31 A typ.	0.5 A typ.	0.57 A typ.	0.58 A typ.	
	Current	230 VAC input *6	0.2 A typ.	0.21 A typ.	0.2 A typ.	0.32 A typ.	0.37 A typ.	0.36 A typ.	
Innut	Power factor	230 VAC input, 100% load	0.42 min.	0.21 A typ.	0.2 A typ.	0.43 min.	0.42 min.	0.43 min.	
Input	Fower lactor						0.42 11111.	0.43 mm.	
	Leakage current	115 VAC input		0.14 mA typ. 0.13 mA typ.					
		230 VAC input	0.25 mA typ.			0.24 mA typ.			
	Inrush current *2 (for	115 VAC input	16 A typ			16 A typ			
	a cold start at 25°C) 230 VAC input		32 A typ.			32 A typ.	1	I	
	Rated output current	nt	3 A	1.2 A	0.65 A	5 A	2.5 A	1.3 A	
	Boost current		3.6 A	1.44 A	0.78 A	6 A	3 A	1.56 A	
	Voltage adjustment	-	-10% to 15% (with	n V.ADJ) (guarante	eed)				
	Ripple & Noise voltage *4	100 to 240 VAC input, 100% load *6	60 mVp-p max. at 20 MHz of bandwidth	50 mVp-p max.at 20 MHz of bandwidth	30 mVp-p max. at 20 MHz of bandwidth				
	Input variation influ	ience *8	0.4% max.			0.4% max.			
Output	Load variation influ	ence *7	0.8% max.			0.8% max.			
·	Temperature variation influence	115 to 230 VAC input	0.05%/°C max.			0.05%/°C max.			
		115 VAC input *6	530 ms typ.	520 ms typ.	580 ms typ.	550 ms typ.	550 ms typ.	600 ms typ.	
	Start up time *2	230 VAC input *6	330 ms typ.	400 ms typ.	400 ms typ.	430 ms typ.	490 ms typ.	480 ms typ.	
		115 VAC input *6	28 ms typ.	29 ms typ.	32 ms typ.	33 ms typ.	36 ms typ.	23 ms typ.	
	Hold time *2	230 VAC input *6	134 ms typ.	138 ms typ.	134 ms typ.	177 ms typ.	170 ms typ.	154 ms typ.	
	Overload protection		Yes, automatic res		ro i no typ.	Yes, automatic re		To This typ.	
	Overvoltage protect		Yes, 130% or higher of rated output voltage, power shut off (shut off the input voltage and turn on the input again)						
Additional	Series operation		Yes (For up to two Power Supplies, external diodes are required.)						
unctions			Yes (For up to two Power Supplies, external diodes are required.) Yes (Refer to Safety Precautions) (For up to two Power Supplies)						
	Parallel operation		Yes (LED: Green), lighting from 80% to 90% or more of rated voltage						
	Output indicator								
			3.0 kVAC for 1 min. (between all input terminals and output terminals), current cutoff 20 mA						
Insulation	Withstand voltage		2.0 kVAC for 1 min. (between all input terminals and PE terminals), current cutoff 20 mA						
			1.0 kVAC for 1 min. (between all output terminals and PE terminals), current cutoff 20 mA						
	Insulation resistant		100 M $\Omega$ min. (between all output terminals and all input terminals/PE terminals) at 500 VDC						
	Ambient operating		-40 to 70°C (Derating is required according to the temperature. Refer to <i>Engineering Data</i> ) (with no condensation or icing)						
	Storage temperatur		-40 to 85°C (with no condensation or icing)						
Environment	Ambient operating	humidity	0% to 95% (Storage humidity: 0% to 95%)						
	Vibration resistance	e	10 to 55 Hz, 0.375 mm half amplitude for 2 h each in X, Y, and Z directions						
	Shock resistance		150 m/s <sup>2</sup> , 3 times each in ±X, ±Y, and ±Z directions						
Poliobility	MTBF		135,000 hrs min.						
Reliability	Life expectancy *9		10 years min.						
	Weight		150 g max.			195 g max.			
Construction	Cooling fan		No			·			
	Degree of protectio	n	IP20 by EN/IEC 60529						
	Harmonic current e		Conforms to EN 61000-3-2						
		Conducted Emissions	Conforms to EN 6	1204-3 Class B. E	N 55011 Class B				
	EMI	Radiated Emissions		1204-3 Class B, E					
	EMS			,					
Standards	Approved Standard	ls	Conforms to EN 61204-3 high severity levels UL Listed: UL 508 (Listing, Class2 Output: Per UL 1310) UL UR: UL 62368-1 (Recognition) cUL: CSA C22.2 No.107.1 (Class2 Output: Per CSA C22.2 No.223) cUR:CSA C22.2 No.62368-1 EN/VDE: EN 50178, EN 62368-1						
			PELV (EN 60204- EN 61558-2-16						
	Conformed Standar	rds		/ 2011, TR CU 020	) / 2011)				
			RCM (EN61000-6						
			(	,					
	Marine Standards		Lloyd's register *						
	SEMI		Conforms to F47-0	0706 ( 200 to 240	vac input)				

\*1. Do not use an inverter output for the Power Supply. Inverters with an output frequency of 50/60 Hz are available, but the rise in the internal temperature of the Power Supply

\*1. Do not use an inverter output for the Power Supply. Inverters with an output frequency of 50/60 Hz are available, but the rise in the internal temperature of the Power Supply may result in ignition or burning.
\*2. For a cold start at 25°C. Refer to *Engineering Data* on page 9 to 11 for details.
\*3. If the output voltage adjuster (V. ADJ) is turned, the voltage will increase by more than +15% of the voltage adjustment range. When adjusting the output voltage, confirm the actual output voltage from the Power Supply and be sure that the load is not damaged.
\*4. A characteristic when the ambient operating temperature is between -25 to 70°C.
\*5. Refer to *Overvoltage Protection* on page 10 for the time when input voltage shuts off and input turns on again.
\*6. The value is when both rated output voltage and rated output current are satisfied.
\*7. 100 to 240 VAC input, in the range of 0 A to the rated output voltage is gradually changed within the allowable input voltage range at the rated output voltage and rated output current.
\*8. Refer to *Recommended Replacement Periods and Periodic Replacement for Preventive Maintenance* on page 23 for details.
\*10. Safety Standards for a DC Input
The following safety standards apply to a DC input: UL 62368-1, cUR (CSA C22.2 No. 62368-1), EN 50178, EN 62368-1, and Lloyd's. For a DC input, safety is ensured by an external fuse.
Select an external fuse that meets the following conditions.
S8VK-G015\_: 350 VDC min, 3 A
S8VK-G015\_: 350 VDC min, 4 A
\*11.Clang filter "CAT2035-0930" manufactured by SCHAFFNER Corporation. or equivalent should be installed in the cable connected to the input - output terminals of S8VK-G series.
\*12.At -40 to -25°C, time will be required before the rated output voltage is output after the input voltage is input. Also, the ripple noise value may exceed the value shown in the above table.

		Power rating	6	0 W	120 W		
Item		Output voltage (VDC)	12 V	24 V	24 V		
Efficiency		230 VAC input *6	85% typ.	88% typ.	89% typ.		
	Voltage range *1		Single-phase, 85 to 264 VAC, 90	to 350 VDC *10			
	Frequency *1		50/60 Hz (47 to 450 Hz)		50/60 Hz (47 to 63 Hz)		
		115 VAC input *6	1.0 A typ.	1.1 A typ.	1.3 A typ.		
	Current	230 VAC input *6	0.6 A typ.	0.7 A typ.	0.7 A typ.		
nput	Power factor	230 VAC input, 100% load	0.46 min.	0.94 min.			
		115 VAC input	0.16 mA typ.	0.24 mA typ.			
	Leakage current	230 VAC input	0.30 mA typ.		0.38 mA typ.		
	Inrush current *2 (for	115 VAC input	16 A typ.	16 A typ.			
	a cold start at 25°C)	230 VAC input	32 A typ.		32 A typ.		
	Rated output current		4.5 A	2.5 A	5 A		
		n	4.5 A 5.4 A	3 A	6 A		
	Boost current				0 A		
	Voltage adjustment	-	-10% to 15% (with V. ADJ) (guar		150		
	Ripple & Noise voltage *4	100 to 240 VAC input, 100% load *6	150 mVp-p max. at 20 MHz of bandwidth	50 mVp-p max. at 20 MHz of bandwidth	150 mVp-p max. at 20 MHz of bandwidth		
	-		0.4% max.		0.4% max.		
Dutput	Input variation influ		0.4% max.		0.4% max.		
Julput	Load variation influ	ence */	U.0 % IIIdX.		0.0% IIIax.		
	Temperature variation influence	115 to 230 VAC input	0.05%/°C max.		0.05%/°C max.		
	Start up time *2	115 VAC input *6	570 ms typ.	650 ms typ.	790 ms typ.		
	Start up time *2	230 VAC input *6	430 ms typ.	500 ms typ.	750 ms typ.		
		115 VAC input *6	26 ms typ.	25 ms typ.	42 ms typ.		
	Hold time *2	230 VAC input *6	139 ms typ.	129 ms typ.	42 ms typ.		
	Overload protection		Yes, automatic reset	Yes, automatic reset			
	Overvoltage protection *5		Yes, 130% or higher of rated output voltage, power shut off (shut off the input voltage and turn on the input again)				
unctions	Series operation		Yes (For up to two Power Supplies, external diodes are required.)				
	Parallel operation		Yes (Refer to Safety Precautions) (For up to two Power Supplies)				
	Output indicator		Yes (LED: Green), lighting from 80% to 90% or more of rated voltage				
			3.0 kVAC for 1 min. (between all input terminals and output terminals), current cutoff 20 mA				
	Withstand voltage		2.0 kVAC for 1 min. (between all input terminals and PE terminals), current cutoff 20 mA				
nsulation	Withstand Voltage		1.0 kVAC for 1 min. (between all output terminals and PE terminals), current cutoff 20 mA				
	Insulation resistance	e		•	1		
	Ambient operating		100 MΩ min. (between all output terminals and all input terminals/PE terminals) at 500 VDC -40 to 70°C (Derating is required according to the temperature. Refer to <i>Engineering Data</i> ) (with no condensation or icin				
	Storage temperatur		-40 to 85°C (with no condensation or icing)				
Environment	Ambient operating		0% to 95% (Storage humidity: 0% to 95%)				
Linvironment	Vibration resistance		10 to 55 Hz, 0.375 mm half amplitude for 2 h each in X, Y, and Z directions				
	Shock resistance	2	$150 \text{ m/s}^2$ , 3 times each in ±X, ±Y, ±Z directions				
	MTBF		135,000 hrs min.				
Reliability	Life expectancy *9		10 years min.				
			260 g max.		620 g max.		
	Weight		No				
Construction	Cooling fan						
Construction	Cooling fan Degree of protectio	n	IP20 by EN/IEC 60529				
Construction	Degree of protectio		IP20 by EN/IEC 60529 Conforms to EN 61000-3-2				
Construction	Degree of protectio Harmonic current e	missions	Conforms to EN 61000-3-2	N 55011 Class B			
Construction	Degree of protectio Harmonic current e	missions Conducted Emissions	Conforms to EN 61000-3-2 Conforms to EN 61204-3 Class B, E				
Construction	Degree of protectio Harmonic current e EMI	missions	Conforms to EN 61000-3-2 Conforms to EN 61204-3 Class B, E Conforms to EN 61204-3 Class B, E	N 55011 Class B			
	Degree of protectio Harmonic current e	missions Conducted Emissions Radiated Emissions	Conforms to EN 61000-3-2 Conforms to EN 61204-3 Class B, E	N 55011 Class B ity levels / only Class2 Output: Per UL 1310			
	Degree of protectio Harmonic current e EMI EMS	missions Conducted Emissions Radiated Emissions	Conforms to EN 61000-3-2 Conforms to EN 61204-3 Class B, E Conforms to EN 61204-3 Class B, E Conforms to EN 61204-3 Class B, E Conforms to EN 61204-3 high sever UL Listed: UL 508 (Listing, For 60 W UL UR: UL 62368-1 (Recognition) cUL: CSA C22.2 No.107.1 (For 60 V cUR: CSA C22.2 No.62368-1 EN/VDE: EN 50178, EN 62368-1 PELV (EN 60204-1, EN 50178)	N 55011 Class B ity levels / only Class2 Output: Per UL 1310			
	Degree of protectio Harmonic current e EMI EMS	missions Conducted Emissions Radiated Emissions S	Conforms to EN 61000-3-2 Conforms to EN 61204-3 Class B, E Conforms to EN 61204-3 Class B, E Conforms to EN 61204-3 Class B, E Conforms to EN 61204-3 high sever UL Listed: UL 508 (Listing, For 60 W UL UR: UL 62368-1 (Recognition) cUL: CSA C22.2 No.107.1 (For 60 V CUR: CSA C22.2 No.62368-1 EN/VDE: EN 50178, EN 62368-1 PELV (EN 60204-1, EN 50178) EN 61558-2-16	N 55011 Class B ity levels / only Class2 Output: Per UL 1310 V only Class2 Output: Per CSA C2			
Construction	Degree of protectio Harmonic current e EMI EMS Approved Standard	missions Conducted Emissions Radiated Emissions S	Conforms to EN 61000-3-2 Conforms to EN 61204-3 Class B, E Conforms to EN 61204-3 Class B, E Conforms to EN 61204-3 Class B, E Conforms to EN 61204-3 high sever UL Listed: UL 508 (Listing, For 60 W UL UR: UL 62368-1 (Recognition) cUL: CSA C22.2 No. 107.1 (For 60 V UR: CSA C22.2 No. 62368-1 EN/VDE: EN 50178, EN 62368-1 PELV (EN 60204-1, EN 50178) EN 61558-2-16 EAC (TR CU 004 / 2011, TR CU 020	N 55011 Class B ity levels / only Class2 Output: Per UL 1310 V only Class2 Output: Per CSA C2			
	Degree of protectio Harmonic current e EMI EMS Approved Standard	missions Conducted Emissions Radiated Emissions S	Conforms to EN 61000-3-2 Conforms to EN 61204-3 Class B, E Conforms to EN 61204-3 Class B, E Conforms to EN 61204-3 Class B, E Conforms to EN 61204-3 high sever UL Listed: UL 508 (Listing, For 60 W UL UR: UL 62368-1 (Recognition) cUL: CSA C22.2 No.107.1 (For 60 V CUR: CSA C22.2 No.62368-1 EN/VDE: EN 50178, EN 62368-1 PELV (EN 60204-1, EN 50178) EN 61558-2-16	N 55011 Class B ity levels / only Class2 Output: Per UL 1310 V only Class2 Output: Per CSA C2			

\*1. Do not use an inverter output for the Power Supply. Inverters with an output frequency of 50/60 Hz are available, but the rise in the internal temperature of the Power Supply

\*1. Do not use an inverter output for the Power Supply. Inverters with an output frequency of 50/60 Hz are available, but the rise in the internal temperature of the Power Supply may result in ignition or burning.
\*2. For a cold start at 25°C. Refer to *Engineering Data* on page 9 to 11 for details.
\*3. If the output voltage adjuster (V. ADJ) is turned, the voltage will increase by more than +15% of the voltage adjustment range. When adjusting the output voltage, confirm the actual output voltage from the Power Supply and be sure that the load is not damaged.
\*4. A characteristic when the ambient operating temperature is between -25 to 70°C.
\*5. Refer to *Overvoltage Protection* on page 10 for the time when input voltage shuts off and input turns on again.
\*6. The value is when both rated output voltage and rated output current are satisfied.
\*7. 100 to 240 VAC input, in the range of 0 A to the rated output current are satisfied.
\*10. Safetr to *Recommended Replacement Periods and Periodic Replacement for Preventive Maintenance* on page 23 for details.
\*10. Safety Standards for a D C Input: UL 62368-1, cUR (CSA C22.2 No. 62368-1), EN 50178, EN 62368-1, and Lloyd's. For a DC input, safety is ensured by an external fuse.
Select an external fuse that meets the following conditions. S8VK-G12024: 350 VDC min, 6 A S8VK-G12035-030° manufactured by TDK Corporation. or equivalent should be installed in the cable connected to the input - output terminals of S8VK-G series.
\*11. Clang filter "FN2080-10-06" manufactured by SCHAFFNER Corporation. or equivalent should be connected to the lnput terminals of S8VK-G series.
\*12. At -40 to -25°C, time will be required before the rated output voltage is output after the input voltage is input. Also, the ripple noise value may exceed the value shown in the above table.

		Power rating	24	0 W	48	0 W	
Item		Output voltage (VDC)	24 V	48 V	24 V	48 V	
Efficiency		230 VAC input *6	92% typ.		93% typ.		
	Voltage range *1		Single-phase, 85 to 264	/AC, 90 to 350 VDC *10			
	Frequency *1		50/60 Hz (47 to 63 Hz)				
	a	115 VAC input *6	2.4 A typ. 4.7 A typ.				
	Current	230 VAC input *6	1.3 A typ.		2.3 A typ.		
nput	Power factor	230 VAC input, 100% load	0.9 min.		0.97 min.		
		115 VAC input	0.23 mA typ.		0.3 mA typ.		
	Leakage current	230 VAC input	0.33 mA typ.		0.49 mA typ.		
	Inrush current *2 (for	115 VAC input	16 A typ.		16 A typ.		
	a cold start at 25°C)	230 VAC input	32 A typ.		32 A typ.		
	Rated output currer	•	10 A	5 A	20 A	10 A	
	Boost current		12 A	6 A	24 A	12 A	
	Voltage adjustment range *3		-10% to 15% (with V.AD.			1	
	Ripple & Noise	100 to 240 VAC input,	180 mVp-p max.	350 mVp-p max.	230 mVp-p max.	470 mVp-p max.	
	voltage *4	100% load *6	at 20 MHz of bandwidth	at 20 MHz of bandwidth	at 20 MHz of bandwidth	at 20 MHz of bandwidth	
-	Input variation influ	ence *8	0.4% max.	ł	0.4% max.	ļ	
Dutput	Load variation influence *7		0.8% max.		0.8% max.		
		115 to 230 VAC input	0.05%/°C max.		0.05%/°C max.		
		115 VAC input *6	250 ms typ.	290 ms typ.	380 ms typ.		
	Start up time *2	230 VAC input *6	250 ms typ.	290 ms typ.	260 ms typ.		
		115 VAC input *6	44 ms typ.	43 ms typ.	40 ms typ.		
	Hold time *2	230 VAC input *6	44 ms typ.	ie nie typ.	50 ms typ.		
	Overload protection		Yes, automatic reset		Yes, automatic reset		
	Overvoltage protection *5		Yes, 130% or higher of rated output voltage, power shut off (shut off the input voltage and turn on the input aga				
Additional	Series operation		Yes (For up to two Power Supplies, external diodes are required.)				
P			Yes (Refer to Safety Precautions) (For up to two Power Supplies)				
	Parallel operation		Yes (LED: Green), lighting from 80% to 90% or more of rated voltage				
0	Output indicator		3.0 kVAC for 1 min. (between all input terminals and output terminals), current cutoff 20 mA				
	Withstand voltage		2.0 kVAC for 1 min. (between all input terminals and output terminals), current cutoff 20 mA				
nsulation			1.0 kVAC for 1 min. (between all output terminals and PE terminals), current cutoff 20 mA				
			100 M $\Omega$ min. (between all output terminals and PE terminals), current cuton 20 mA 100 M $\Omega$ min. (between all output terminals and all input terminals)/PE terminals) at 500 VDC				
	Insulation resistance		-40 to 70 °C (Derating is required according to the temperature. Refer to Engineering Data) (with no condensation or icing)				
	Ambient operating	-	-40 to 70 °C (Derating is required according to the temperature. Here to Engineering Data) (with no condensation or icing) -40 to 85°C (with no condensation or icing)				
	Storage temperatur			0,			
Environment	Ambient operating		0% to 95% (Storage hum	•			
	Vibration resistance	9		alf amplitude for 2 h each i	n X, Y, and Z directions		
	Shock resistance		150 m/s <sup>2</sup> , 3 times each in ±X, ±Y, ±Z directions 135,000 hrs min.				
Reliability	MTBF						
•	Life expectancy *9		10 years min.				
	Weight		900 g max. 1,500 g max.				
Construction	Cooling fan		No				
	Degree of protection		IP20 by EN/IEC 60529				
	Harmonic current e		Conforms to EN 61000-3-2				
	ЕМІ	Conducted Emissions		Class B, EN 55011 Class			
		Radiated Emissions		Class B, EN 55011 Class	В		
	EMS		Conforms to EN 61204-3				
Standards	Approved Standards		UL Listed: UL 508 (Listing) UL UR: UL 62368-1 (Recognition) cUL: CSA C22.2 No.107.1 cUR: CSA C22.2 No.62368-1 EN/VDE: EN 50178, EN 62368-1				
	Conformed Standar	ds	PELV (EN 60204-1, EN 5 EN 61558-2-16	50178)			
			EAC (TR CU 004 / 2011,	TH CU 020 / 2011)			
			RCM (EN61000-6-4)				
	Marine Standards		Lloyd's register *10 *11				
	SEMI		Conforms to F47-0706 (2	200 to 240 VAC input)			

\$1. Do not use an inverter output for the Power Supply. Inverters with an output frequency of 50/60 Hz are available, but the rise in the internal temperature of the Power Supply may result in ignition or burning.
\$2. For a cold start at 25°C. Refer to *Engineering Data* on page 9 to 11 for details.
\$3. If the output voltage adjuster (V. ADJ) is turned, the voltage will increase by more than +15% of the voltage adjustment range. When adjusting the output voltage, confirm the actual output voltage from the Power Supply and be sure that the load is not damaged.
\$4. A characteristic when the ambient operating temperature is between -25 to 70°C.
\$5. Refer to *Overvoltage Protection* on page 10 for the time when input voltage shuts off and input turns on again.
\$6. The value is when both rated output voltage and rated output current estisfied.
\$7. 100 to 240 VAC input, in the range of 0 A to the rated output current
\$8. This is the maximum variation in the output voltage and rated output current
\$9. Refer to *Recommended Replacement Periods and Periodic Replacement for Preventive Maintenance* on page 23 for details.
\$10. Safety Standards for a DC Input
The following safety is ensured by an external fuse.
S8VK-G240 : 350 VDC min, 8 A
S8VK-G240 : 350 VDC min, 12 A
\$11. Clamp filter "ZCAT2035-0930" manufactured by TDK Corporation. or equivalent should be installed in the cable connected to the input - output terminals of S8VK-G series.
\$12. At -40 to -25°C, time will be required before the rated output voltage is output after the input voltage is input.
Also, the ripple noise value may exceed the value shown in the above table.

Also, the ripple noise value may exceed the value shown in the above table.

## Connections

## **Block Diagrams**

S8VK-G015 (15 W)



### S8VK-G030 (30 W)



### S8VK-G060 (60 W)



#### S8VK-G12024 (120 W)



### S8VK-G240 (240 W)



S8VK-G480 (480 W)



## **Construction and Nomenclature**

## Nomenclature

**15-W Models** 

120-W Models

S8VK-G12024

S8VK-G015



**30-W Models** 

S8VK-G030

240-W Models

S8VK-G240

3 A



480-W Models S8VK-G480

**60-W Models** 

S8VK-G060







Name	Function
Input terminals (L), (N)	Connect the input lines to these terminals. *1
Protective Earth terminal (PE)	Connect the ground line to this terminal. *2
DC Output terminals (–V), (+V)	Connect the load lines to these terminals.
Output indicator (DC ON: Green)	Lights while a direct current (DC) output is ON.
Output voltage adjuster (V.ADJ)	Use to adjust the voltage.
	Input terminals (L), (N) Protective Earth terminal (PE) DC Output terminals (–V), (+V) Output indicator (DC ON: Green)

\*1. The fuse is located on the (L) side. It is not user-replaceable. For a DC input, connect the positive voltage to the L terminal.
\*2. This is the protective earth terminal specified in the safety standards. Always ground this terminal.

## **Engineering Data**

### **Derating Curve**

15, 30, 240 W (S8VK-G015 , S8VK-G030 , S8VK-G240 )



Note: 1. At less than 90 VAC, the derating is 2.5%/V

- 2. For a DC power input, reduce the load given in the above derating curve by multiplying the following coefficients. S8VK-G015 : 1.0 S8VK-G030 : 0.9
  - S8VK-G240 : 0.8
- This is the guaranteed value for startup. 3.
- A. Standard mounting
- B. Face-up mounting / Side mounting (15W only)

#### 60 W (S8VK-G060



Note: 1. At less than 90 VAC, the derating is 2.5%/V

- 2. For a DC power input, reduce the load given in the above derating curve by multiplying the following coefficients. S8VK-Ğ06000: 0.9
- This is the guaranteed value for startup. 3.
- A. Standard mounting
- B. Face-up mounting

#### 120 W (S8VK-G12024)



Note: 1. At less than 90 VAC, the derating is 2.5%/V

- 2. For a DC power input, reduce the load given in the above derating curve by multiplying the following coefficients. S8VK-G12024: 0.9
  - 3. This is the guaranteed value for startup.
  - A. Standard mounting
  - B. Face-up mounting

#### 480 W (S8VK-G480



- Note: 1. At less than 90 VAC, the derating is 2.5%/V
  - 2. For a DC power input, reduce the load given in the above derating curve by multiplying the following coefficients. S8VK-G480 : 0.8
  - This is the guaranteed value for startup. 3.

  - A. Standard mounting B. Face-up mounting

#### Mounting

(A) Standard (Vertical) mounting



(B) Face-up mounting

(C) Side mounting only for 15 W



Side mounting is only for S8VK-G015

Use a mounting bracket (S82Y-VK15P, sold separately) when the product is mounted horizontally.

Heat dissipation will be adversely affected. When the product is mounted facing horizontally, always place the side with label facing upward.

### **Overload Protection**

The load and the power supply are automatically protected from overcurrent damage by this function.

Overload protection is activated if the output current rises above 121% of the rated current.

When the output current returns within the rated range, overload protection is automatically cleared.



The values shown in the above diagrams are for reference only.

- Note: 1. Internal parts may occasionally deteriorate or be damaged if a short-circuited or overcurrent state continues during operation.
  - Internal parts may possibly deteriorate or be damaged if the Power Supply is used for applications with frequent inrush current or overloading at the load end. Do not use the Power Supply for such applications.

#### **Overvoltage Protection**

Consider the possibility of an overvoltage and design the system so that the load will not be subjected to an excessive voltage even if the feedback circuit in the Power Supply fails. If an excessive voltage that is approximately 130% of the rated voltage or more is output, the output voltage is shut OFF. Reset the input power by turning it OFF for at least three minutes and then turning it back ON again.



The values shown in the above diagram is for reference only.

Note: Do not turn ON the power again until the cause of the overvoltage has been removed.

#### Inrush Current, Startup Time, Output Hold Time



Note: Twice the input current or above will flow during the parallel operation or redundant system. Therefore, check the fusing characteristics of fuses and

operating characteristics of breakers making sure that the external fuses will not burn out and the circuit breakers will not be activated by the inrush current.

#### Two phases application for Single phase models For All Single phase Models, S8VK-G

Basically OMRON single phase power supply can be used on twophases of a 3-phase-system when some of conditions satisfy like below.

- The supplying voltage is below the maximum rated input. OMRON Power supply allows the input voltage equivalent or less than 240 VAC+10%. Please confirm the input voltage between two lines if the input
- Please confirm the input voltage between two lines if the input voltage satisfies this condition before connecting.
  The external protector is needed on N input line to secure a safety. N line has no protection of a fuse internally.

An appropriate fuse or circuit breaker should be connected on N input line like the following.



### **Reference Value**

	Value		
Reliability (MTBF)	Single phase model 15 W: 600,000 hrs 30 W: 580,000 hrs 60 W: 590,000 hrs 120 W: 450,000 hrs 240 W: 360,000 hrs 480 W: 230,000 hrs		
Definition	MTBF stands for Mean Time Between Failures, which is calculated according to the probability of accidental device failures, and indicates reliability of devices. Therefore, it does not necessarily represent a life of the product.		
Life expectancy	10 yrs. Min.		
Definition	The life expectancy indicates average operating hours under the ambient temperature of 40°C and a load rate of 50%. Normally this is determined by the life expectancy of the built-in aluminum electrolytic capacitor.		

## Dimensions

## S8VK-G015 (15 W)



### S8VK-G030 (30 W)



## S8VK-G060 (60 W)





#### S8VK-G12024 (120 W)



S8VK-G240 (240 W)



S8VK-G480 (480 W)





## **DIN Rail (Order Separately)**

Note: All units are in millimeters unless otherwise indicated.

### Mounting Rail (Material: Aluminum) PFP-100N

PFP-50N



#### Mounting Rail (Material: Aluminum) PFP-100N2



End Plate PFP-M



Note: If there is a possibility that the Unit will be subject to vibration or shock, use a steel DIN Rail. Otherwise, metallic filings may result from aluminum abrasion.

## **Mounting Brackets**

Name	Model
Front-mounting bracket (for 15, 30 and 60 W models)	S82Y-VS10F
Front-mounting bracket (for 120, 240 and 480 W models)	S82Y-VK10F
Side-mounting bracket (for 15 W models)	S82Y-VK15P
Side-mounting bracket (for 30 and 60 W models)	S82Y-VS10S
Side-mounting bracket (for 120 W models)	S82Y-VK10S
Side-mounting bracket (for 240 W models)	S82Y-VK20S

Note: Be sure to use the accessory screws.

Mounting screw tightening torque (recommended): 4.43 to 5.31 lb-in (0.5 to 0.6 N·m)





\* You can mount the side of the Power Supply to a DIN Rail by removing the DIN Rail Back-mounting Bracket and then attaching a Side-mounting Bracket to the Power Supply.

## **Safety Precautions**

### Warning Indications

	Indicates a potentially hazardous situation which, if not avoided, may result in minor or moderate injury or in property damage.
Precautions for Safe Use	Supplementary comments on what to do or avoid doing, to use the product safely.
Precautions for Correct Use	Supplementary comments on what to do or avoid doing, to prevent failure to operate, malfunction or undesirable effect on product performance.

### **Meaning of Product Safety Symbols**

	Used to warn of the risk of electric shock under specific conditions.
	Used to warn of the risk of minor injury caused by high temperatures.
0	Used for general mandatory action precautions for which there is no specified symbol.
	Use to indicate prohibition when there is a risk of minor injury from electrical shock or other source if the product is disassembled.

#### 

Minor electric shock, fire, or Product failure may occasionally occur. Do not disassemble, modify, or repair the Product or touch the interior of the Product.



Minor burns may occasionally occur. Do not touch the Product while power is being supplied or immediately after power is turned OFF.



Fire may occasionally occur. Tighten terminal screws to the specified torque (0.5 to 0.6  $\text{N}{\cdot}\text{m}).$ 



Minor injury due to electric shock may occasionally occur. Do not touch the terminals while power is being supplied. Always close the terminal cover after wiring.

Minor electric shock, fire, or Product failure may occasionally occur. Do not allow any pieces of metal or conductors or any clippings or cuttings resulting from installation work to enter the Product.



### Precautions for Safe Use

### Wiring

- Connect the ground completely. A protective earthing terminal stipulated in safety standards is used. Electric shock or malfunction may occur if the ground is not connected completely.
- Minor fire may possibly occur. Ensure that input and output terminals are wired correctly.
- Do not apply more than 75-N force to the terminal block when tightening it.
- Be sure to remove the sheet covering the Product for machining before power-ON so that it does not interfere with heat dissipation.
- Use the following material for the wires to be connected to the S8VK-G to prevent smoking or ignition caused by abnormal loads.

#### **Recommended Wire Type/Cross-sectional Area and Stripping Length**

	IN	IPUT	OL	JTPUT		PE	Wine Stripping
Model	American Wire Gauge	Solid Wire /Stranded Wire	American Wire Gauge	Solid Wire /Stranded Wire	American Wire Gauge	Solid Wire /Stranded Wire	Wire Stripping Length
S8VK-G01505			AWG20 to 12	0.5 to 4 mm <sup>2</sup> /0.5 to 2.5 mm <sup>2</sup>			
S8VK-G01512	AWG24 to 12	0.25 to 4 mm <sup>2</sup> /0.25 to 2.5 mm <sup>2</sup>	AWG22 to 12	0.35 to 4 mm <sup>2</sup> /0.35 to 2.5 mm <sup>2</sup>			
S8VK-G01524	AWG24 to 12		AWG24 to 12	0.25 to 4 mm <sup>2</sup> /0.25 to 2.5 mm <sup>2</sup>			
S8VK-G03005			AWG18 to 12	0.75 to 4 mm <sup>2</sup> /0.75 to 2.5 mm <sup>2</sup>	AWG14 to 12	2.5 to 4 mm <sup>2</sup> / 2.5 to 4 mm <sup>2</sup>	8 to 10 mm
S8VK-G03012		/G24 to 12 0.25 to 4 mm <sup>2</sup> /0.25 to 2.5 mm <sup>2</sup>	AWG20 to 12	0.5 to 4 mm <sup>2</sup> /0.5 to 2.5 mm <sup>2</sup>	AWG14 to 12		
S8VK-G03024			AWG22 to 12	0.35 to 4 mm <sup>2</sup> /0.35 to 2.5 mm <sup>2</sup>			
S8VK-G06012		WG22 to 12 0.35 to 4 mm <sup>2</sup> /0.35 to 2.5 mm <sup>2</sup>	AWG18 to 12	0.75 to 4 mm <sup>2</sup> /0.75 to 2.5 mm <sup>2</sup>			
S8VK-G06024	AWG22 10 12		AWG20 to 12	0.5 to 4 mm <sup>2</sup> /0.5 to 2.5 mm <sup>2</sup>			
S8VK-G12024	AWG22 to 10	0.35 to 6 mm <sup>2</sup> /0.35 to 4 mm <sup>2</sup>	AWG18 to 10	0.75 to 6 mm <sup>2</sup> /0.75 to 4 mm <sup>2</sup>			
S8VK-G24024	AWG20 to 10	0.5 to 6 mm <sup>2</sup>	AWG14 to 10	2.5 to 6 mm <sup>2</sup> /2.5 to 4 mm <sup>2</sup>		2.5 to 6 mm <sup>2</sup> / 2.5 to 4 mm <sup>2</sup>	
S8VK-G24048	$\Delta M(=20 \pm 0.10)$	/0.5 to 4 mm <sup>2</sup>	AWG18 to 10	0.75 to 6 mm <sup>2</sup> /0.75 to 4 mm <sup>2</sup>	AWG14 to 10		
S8VK-G48024		VG16 to 10 1.5 to 6 mm <sup>2</sup> /1.5 to 4 mm <sup>2</sup>	AWG12 to 10	4 to 6 mm <sup>2</sup> /4 mm <sup>2</sup>			
S8VK-G48048			AWG14 to 10	2.5 to 6 mm <sup>2</sup> /2.5 to 4 mm <sup>2</sup>			

• The wire insertion hole, and applicable screwdriver of the terminal block are as follows.

Model	Wire Insertion Hole (Refer to the diagram on the right)		Applicable Screwdriver			
	W	L	No.	Driver Diameter	Length	
S8VK-G01505						
S8VK-G01512						
S8VK-G01524						
S8VK-G03005	2.7		#1	3.5 mm max.	4.5 mm min.	
S8VK-G03012	2.7		#1	5.5 mm max.	4.5 mm mm.	
S8VK-G03024						
S8VK-G06012		2.9				
S8VK-G06024						
S8VK-G12024						
S8VK-G24024						
S8VK-G24048	2.9		#2	4.9 mm max.	10 mm min.	
S8VK-G48024	1					
S8VK-G48048	1					

### **Recommended ferrules and Crimp Tools**

Applica	ble wire	Ferrules	Stripping length (mm)	Re	commended ferrules	•
(mm²)	(AWG)	Conduct length (Ferrules used)		Phoenix Contact product	Weidmuller product	Nichifu product
0.05	04	8	10	AI 0.25-8	H0.25/12	
0.25 24		10	12	AI 0.25-10		
0.34 22		8	10	AI 0.34-8	H0.34/12	TE0.5-8
		10	12	AI 0.34-10		TE0.5-10
0.50 20		8	10	AI 0.5-8	H0.5/14	TE0.75-8
0.50 20	10	12	AI 0.5-10		TE0.75-10	
0.75	10	8	10	AI 0.75-8	H0.75/14	TE1.0-8
0.75 18	10	12	AI 0.75-10		TE1.0-10	
1.5	16	8	10	Al 1.5-8	H1.5/14	TE1.5-8
1.5	10	10	12	Al 1.5-10		TE1.5-10
0.5	14	8	10	AI 2.5-8	H2.5/15	TE2.5-8
2.5	14	10	12	AI 2.5-10		TE2.5-10
3.5	12	10	12	AI 4-10	H4.0/18	TE4.0-10
6	10	12	16	AI 6-12	H6.0/20	TE6.0-12
Recomm	ended crimp	tool		CRIMPFOX10S		

Note: 1. Make sure that the outer diameter of the wire is smaller than the inner diameter of the insulating sleeve of the recommended ferrule.
2. Make sure that the ferrule processing dimensions conform to the following figure.



#### Installation Environment

- Do not use the Power Supply in locations subject to shocks or vibrations. In particular, install the Power Supply as far away as possible from contactors or other devices that are a vibration source. For usage onboard a ship, always attach an End Plate (PFP-M) to both sides of the Power Supply to hold the Power Supply in place.
- Install the Power Supply well away from any sources of strong, high-frequency noise and surge.

#### **Operating Life**

 The life of a Power Supply is determined by the life of the electrolytic capacitors used inside. Here, Arrhenius Law applies, i.e., the life will be cut in half for each rise of 10°C or the life will be doubled for each drop of 10°C. The life of the Power Supply can thus be increased by reducing its internal temperature.

#### **Ambient Operating and Storage Environments**

- Store the Power Supply at a temperature of -40 to 85°C and a humidity of 0% to 95%.
- Do not use the Power Supply in areas outside the derating curve otherwise, internal parts may occasionally deteriorate or be damaged.
- Use the Power Supply at a humidity of 0% to 95%.
- Do not use the Power Supply in locations subject to direct sunlight.
- Do not use the Power Supply in locations where liquids, foreign matter, or corrosive gases may enter the interior of Products.

#### Mounting

- Take adequate measures to ensure proper heat dissipation to increase the long-term reliability of the Product. Be sure to allow convection in the atmosphere around devices when mounting. Do not use in locations where the ambient temperature exceeds the range of the derating curve.
- When cutting out holes for mounting, make sure that cuttings do not enter the interior of the Products.



\*1. Convection of air
\*2. 20 mm min.

- Improper mounting will interfere with heat dissipation and may occasionally result in deterioration or damage of internal parts. Use the Product within the derating curve for the mounting direction that is used.
- Use a mounting bracket when the Product is mounted facing horizontally.
- Heat dissipation will be adversely affected. When the Product is mounted facing horizontally, always place the side with the label facing upward.

#### **DIN Rail Mounting**

To mount the Block on a DIN Rail, hook portion (A) of the Block onto the rail and press the Block in direction (B).



To dismount the Block, pull down portion (C) with a flat-blade screwdriver and pull out the Block.



## **Power Boost Function**

#### For All Models

Power Boost is a function that can output the temporary repeated boost current larger than the rated current.

However, it should meet the following four Boost current conditions. 1. Time that the boost current flows: t1

- 2. The maximum value of the boost current: lp
- **3.** The average output current: lave
- 4. The time ratio of the boost current flow: Duty

#### Note: Boost current conditions

• t1	≤ 10 s
• Ip	≤ Rated boost current
<ul> <li>lave</li> </ul>	≤ Rated current

Duty=
$$\frac{t1}{t1 + t2} \times 100 \, [\%] \le 30\%$$



- Do not allow the boost current to continue for more than 10 seconds. Also, do not let the duty cycle exceed the boost current conditions. These conditions may damage the Power supply.
- Ensure that the average current of one cycle of the boost current does not exceed the rated output current. This may damage the Power Supply.
- Lessen the load of the boost load current by adjusting the ambient temperature and the mounting direction.

#### **Overcurrent Protection**

- Internal parts may possibly deteriorate or be damaged if a short-circuited or overcurrent state continues during operation.
- Internal parts may possibly deteriorate or be damaged if the Power Supply is used for applications with frequent inrush current or overloading at the load end. Do not use the Power Supply for such applications.
- The DC ON indicator (green) flashes if the overload protection function operates.

### **Charging a Battery**

If you connect a battery as the load, install overcurrent control and overvoltage protection circuits.

#### Output Voltage Adjuster (V.ADJ)

- The output voltage adjuster (V.ADJ) may possibly be damaged if it is turned with unnecessary force. Do not turn the adjuster with excessive force.
- After completing output voltage adjustment, be sure that the output capacity or output current does not exceed the rated output capacity or rated output current.

### **Series Operation**

Two power supplies can be connected in series.



Note: 1. The diode is connected as shown in the figure. If the load is short-circuited, a reverse voltage will be generated inside the Power Supply. If this occurs the Power Supply may possibly deteriorate or be damaged. Always connect a diode as shown in the figure. Select a diode having the following ratings.

Туре	Schottky Barrier diode
Dielectric strength (VRRM)	Twice the rated output voltage or above
Forward current (IF)	Twice the rated output current or above

 Although Products having different specifications can be connected in series, the current flowing through the load must not exceed the smaller rated output current.

#### **Making Positive/Negative Outputs**

 The outputs are floating outputs (i.e., the primary circuits and secondary circuits are separated). You can therefore make positive and negative outputs by using two Power Supplies. You can make positive and negative outputs with any of the models.

If positive and negative outputs are used, connect Power Supplies of the same model as in the following figure. (Combinations with different output capacities or output voltages can be made. However, use the lower of the two maximum rated output currents as the current to the loads.)



 Depending on the model, internal circuits may be damaged due to startup failure when the power is turned ON if loads such as a servomotor or operational amplifier may operate in series. Therefore, connect bypass diodes (D1, D2) as shown in the following figure.



• Use the following information as a guide to the diode type, dielectric strength, and current.

Туре	Schottky Barrier diode
Dielectric strength (VRRM)	Twice the rated output voltage or above
Forward current (IF)	Twice the rated output current or above

### Parallel Operation

Parallel operation is used when the output current from one Power Supply is insufficient for the load. Power Supplies are connected in parallel to increase the output current.

The parallel operation of S8VK-G is possible to increase the output power.

However please consider the following notes when the parallel operation must be done.

- 1. The range of ambient temperature for Parallel operation is –25 to  $40^{\circ}$ C.
- 2. Up to two of the same model can be connected in parallel.
- Adjust the output voltage difference of each Power Supply to 50 mV or less, using the output voltage adjuster (V. ADJ).
- 4. There is no current balancing function for S8VK-G. A high output voltage unit may work at overcurrent state and in this situation, a life of a Power Supply will be extremely short. After adjusting the output voltage, confirm the output current of the two Power Supplies balances.
- 5. Using the parallel operation will not satisfy UL1310 Class2 output.
- 6. For Parallel Operation, to balance the current of the each unit, the length and thickness of each wire connected to the load and each unit must be same as much as possible.
- If you use the 15-W to 240-W S8VK-G in parallel operation, the output voltage may drop by several volts if the load changes rapidly (e.g., if the load starts or is disconnected). If operation becomes unstable, use the S8VK-R as shown in the diagram. Refer to the S8VK-R datasheet (Catalog No.: T059) for S8VK-R specifications and the model number for each capacity.



8. If you use the 480-W S8VK-G in parallel operation, the output voltage may drop by several volts if the load changes rapidly (e.g., if the load starts or is disconnected). If operation becomes unstable, connect a diode as shown in the diagram.



• Use the following information as a guide to the diode type, dielectric strength, and current.

Туре	Schottky Barrier diode
Dielectric strength (VRRM)	Twice the rated output voltage or above
Forward current (IF)	Twice the rated output current or above

### **Backup Operation**

Backup operation is possible if you use two Power Supplies of the same model.

 $\ensuremath{\mathsf{Even}}$  if one Power Supplies fails, operation can be continued with the other Power Supply.

Make sure that the maximum load does not exceed the capacity of one Power Supply.

For backup operation, connect the S8VK-R as shown in the figure.



Refer to the S8VK-R datasheet (Catalog No.: T059) for S8VK-R specifications and the model number for each capacity.

### In Case There Is No Output Voltage

The possible cause for no output voltage may be that the overcurrent or overvoltage protection has operated. The internal protection may operate if a large amount of surge voltage such as a lightening surge occurs while turning ON the power supply.

In case there is no output voltage, please check the following points before contacting us:

- Checking overload protected status: Check whether the load is in overload status or is short-circuited. Remove wires to load when checking.
- Checking overvoltage or internal protection: Turn the power supply OFF once, and leave it OFF for at least 3 minutes. Then turn it ON again to see if this clears the condition.

### Audible Noise at Power ON

#### (120-W, 240-W, and 480-W Models)

A harmonic current suppression circuit is built into the Power Supply. This circuit can create noise when the input is turned ON, but it will last only until the internal circuits stabilize and does not indicate any problem in the Product.

## Period and Terms of Warranty

## Warranty Period

The Power Supply warranty is valid for a period of Five years from the date of shipment from the factory.

## **Terms of Warranty**

The warranty is valid only for the following operating conditions.

1. Average ambient operating temperature of the Power Supply: 40°C max.

2. Average load rate of 80% max.

3. Mounting method: Standard mounting

Note: The maximum ratings must be within the derating curve.

If the Power Supply fails for reasons attributable to OMRON within the above warranty period, OMRON will repair or replace the faulty part of the Power Supply at the place of purchase or the place where the Power Supply delivered without charge. This warranty does not cover the following types of failures.

(1) Failures that result from handling or operation of the Power Supply under conditions or in environments that are not given in this document and not given in any other specifications exchanged between OMRON and the customer

(2) Failures that originate in causes other than the delivered product itself

(3) Failures caused by disassembly, modification, or repair of the Power Supply by anyone other than OMRON

(4) Failures caused by applications or uses for which the Power Supply was not originally intended.

- (5) Failures caused by factors that could not be anticipated with the scientific or technical knowledge available when the Power Supply was shipped.
- (6) Failures caused by other causes for which OMRON is not responsible, such as natural disasters and other acts of God.

This warranty is limited to the individual Power Supply that was delivered and does not cover any secondary, subsequent, or related damages.

# **Recommended Replacement Periods and Periodic Replacement for Preventive Maintenance**

The recommended replacement period for preventive maintenance is greatly influenced by the application environment of the Power Supply. As a guideline, the recommended replacement period is 7 to 10 years.\*

S8VK-X is equipped with a replacement time calculation function, and the approximate number of years until replacement based on the ambient temperature and load rate can be checked via indicator (types with indication monitors only) or communication.

To prevent failures or accidents that can be caused by using a Power Supply beyond its service live, we recommend that you replace the Power Supply as early as possible within the recommended replacement period.

However, bear in mind that the recommended replacement period is for reference only and does not guarantee the life of the Power Supply.

Many electronic components are used in the Power Supply and the Power Supply depends on the correct operation of these components to achieve the original Power Supply functions and performance. However, the influence of the ambient temperature on aluminum electrolytic capacitors is large, and the service life is reduced by half for each 10°C rise in temperature (Arrhenius law). When the capacity reduction life of the electrolytic capacitor is reached, the Power Supply failures or accidents may occur. We therefore recommend that you replace the Power Supply periodically to minimize product failures or accidents in advance.

\* The recommended replacement period applies under the following conditions: rated input voltage, load rate of 50% max., ambient temperature of 40°C max., and the standard mounting method.

This product model is designed with a service life of 10 years minimum under the above conditions.



#### OMRON AUTOMATION AMERICAS HEADQUARTERS • Chicago, IL USA • 847.843.7900 • 800.556.6766 • automation.omron.com

OMRON CANADA, INC. • HEAD OFFICE Toronto, ON, Canada • 416.286.6465 • 866.986.6766 • automation.omron.com

OMRON ELECTRONICS DE MEXICO • HEAD OFFICE Ciudad de México • 52.55.5901.4300 • 01.800.386.6766 • mela@omron.com

OMRON ELECTRONICS DE MEXICO • SALES OFFICE San Pedro Garza García, N.L. • 81.12.53.7392 • 01.800.386.6766 • mela@omron. com

OMRON ELECTRONICS DE MEXICO • SALES OFFICE Eugenio Garza Sada,León, Gto • 01.800.386.6766 • mela@omron.com

Authorized Distributor:

#### OMRON ELETRÔNICA DO BRASIL LTDA • HEAD OFFICE São Paulo, SP, Brasil • 55 11 5171-8920 • automation.omron.com

OMRON ARGENTINA • SALES OFFICE Buenos Aires, Argentina • +54.11.4521.8630 • +54.11.4523.8483 mela@omron.com

OTHER OMRON LATIN AMERICA SALES +54.11.4521.8630 • +54.11.4523.8483 • mela@omron.com

#### **Controllers & I/O**

Machine Automation Controllers (MAC) 
 Motion Controllers

Programmable Logic Controllers (PLC) 
 Temperature Controllers 
 Remote I/O

#### Robotics

Industrial Robots 
 Mobile Robots

#### **Operator Interfaces**

• Human Machine Interface (HMI)

#### **Motion & Drives**

- Machine Automation Controllers (MAC) 
   Motion Controllers 
   Servo Systems
- Frequency Inverters

#### Vision, Measurement & Identification

Vision Sensors & Systems • Measurement Sensors • Auto Identification
Systems

#### Sensing

- Photoelectric Sensors Fiber-Optic Sensors Proximity Sensors
- Rotary Encoders
   Ultrasonic Sensors

#### Safety

Safety Light Curtains 
 Safety Laser Scanners 
 Programmable Safety Systems

- Safety Mats and Edges Safety Door Switches Emergency Stop Devices
- Safety Switches & Operator Controls Safety Monitoring/Force-guided Relays

#### **Control Components**

- Power Supplies 
   Timers 
   Counters 
   Programmable Relays
- Digital Panel Meters 
   Monitoring Products

#### Switches & Relays

- Limit Switches 
   Pushbutton Switches 
   Electromechanical Relays
- Solid State Relays

#### Software

Programming & Configuration
 Runtime

© 2020 Omron. All Rights Reserved.